

RESIDENTIAL REPLACEMENT BOILER 2018 IMC Self-Certification Form



NEW CASTLE COUNTY

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

5/26/15
REVISED 4/7/2017
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation. Completed forms must be forwarded to the New Castle County Inspections Division at permits@nccde.org immediately following the installation.

LOT # _____ SUBDIVISION _____ TAX PARCEL _____

PROPERTY ADDRESS _____

HVAC PERMIT # _____

CHECKLIST

Installations shall comply with all applicable New Castle County adopted codes

Specs: _____ BTU Manuf. _____ Model # _____

Fuel type Natural Gas LP Oil

General / Inspection checklist

<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><u>Pass</u></td> <td style="width: 10%;"><u>N/A</u></td> <td style="width: 70%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Manuf. instructions left with appliance</td> <td>IMC 304.1</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Manuf. name, model, etc affixed to appliance</td> <td>IMC 301.6</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Appliance installed in accordance with permit</td> <td>C 6 6.03.013</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Lighting fixture installed (attic & under floor)</td> <td>IMC 306.3.1</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Electrical work installed & inspected if applicable</td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td>DE Title 24 Ch. 14</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Chimney and/or vent connector meets code</td> <td>IMC 803</td> </tr> </table>	<u>Pass</u>	<u>N/A</u>			<input type="checkbox"/>		Manuf. instructions left with appliance	IMC 304.1	<input type="checkbox"/>		Manuf. name, model, etc affixed to appliance	IMC 301.6	<input type="checkbox"/>		Appliance installed in accordance with permit	C 6 6.03.013	<input type="checkbox"/>	<input type="checkbox"/>	Lighting fixture installed (attic & under floor)	IMC 306.3.1	<input type="checkbox"/>	<input type="checkbox"/>	Electrical work installed & inspected if applicable					DE Title 24 Ch. 14	<input type="checkbox"/>	<input type="checkbox"/>	Chimney and/or vent connector meets code	IMC 803	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><u>Pass</u></td> <td style="width: 10%;"><u>N/A</u></td> <td style="width: 70%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Chimney and/or vent connector minimally pitched & properly sized</td> <td>IMC 803.10.5, 801.6</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Masonry chimneys lined per</td> <td>IMC 801.16, IFGC 504.2.9, 504.2.7</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Direct-vent, integral & mech. draft systems per code</td> <td>IMC 804</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Condensate disposal installed per code</td> <td>IMC 307</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Access and service space per code</td> <td>IMC 306</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Piping supported per code</td> <td>IMC 305</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Space/water heating systems provided w/sealed protection</td> <td>IMC 1002.2</td> </tr> </table>	<u>Pass</u>	<u>N/A</u>			<input type="checkbox"/>	<input type="checkbox"/>	Chimney and/or vent connector minimally pitched & properly sized	IMC 803.10.5, 801.6	<input type="checkbox"/>	<input type="checkbox"/>	Masonry chimneys lined per	IMC 801.16, IFGC 504.2.9, 504.2.7	<input type="checkbox"/>	<input type="checkbox"/>	Direct-vent, integral & mech. draft systems per code	IMC 804	<input type="checkbox"/>		Condensate disposal installed per code	IMC 307	<input type="checkbox"/>		Access and service space per code	IMC 306	<input type="checkbox"/>		Piping supported per code	IMC 305	<input type="checkbox"/>	<input type="checkbox"/>	Space/water heating systems provided w/sealed protection	IMC 1002.2
<u>Pass</u>	<u>N/A</u>																																																																
<input type="checkbox"/>		Manuf. instructions left with appliance	IMC 304.1																																																														
<input type="checkbox"/>		Manuf. name, model, etc affixed to appliance	IMC 301.6																																																														
<input type="checkbox"/>		Appliance installed in accordance with permit	C 6 6.03.013																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Lighting fixture installed (attic & under floor)	IMC 306.3.1																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Electrical work installed & inspected if applicable																																																															
			DE Title 24 Ch. 14																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Chimney and/or vent connector meets code	IMC 803																																																														
<u>Pass</u>	<u>N/A</u>																																																																
<input type="checkbox"/>	<input type="checkbox"/>	Chimney and/or vent connector minimally pitched & properly sized	IMC 803.10.5, 801.6																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Masonry chimneys lined per	IMC 801.16, IFGC 504.2.9, 504.2.7																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Direct-vent, integral & mech. draft systems per code	IMC 804																																																														
<input type="checkbox"/>		Condensate disposal installed per code	IMC 307																																																														
<input type="checkbox"/>		Access and service space per code	IMC 306																																																														
<input type="checkbox"/>		Piping supported per code	IMC 305																																																														
<input type="checkbox"/>	<input type="checkbox"/>	Space/water heating systems provided w/sealed protection	IMC 1002.2																																																														

<p><u>Gas</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><u>Pass</u></td> <td style="width: 10%;"><u>N/A</u></td> <td style="width: 70%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Shut off valves installed</td> <td>IFGC 409.1</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Fuel gas piping inspected if req'd</td> <td>IFGC 401.1</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Clearance to combustibles</td> <td>IMC 304.8, 308</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Combustion air provided</td> <td>IMC 701</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Ignition source elevated in hazardous locations</td> <td>IMC 304.3</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Oil tank removed if req'd</td> <td></td> </tr> </table>	<u>Pass</u>	<u>N/A</u>			<input type="checkbox"/>		Shut off valves installed	IFGC 409.1	<input type="checkbox"/>		Fuel gas piping inspected if req'd	IFGC 401.1	<input type="checkbox"/>		Clearance to combustibles	IMC 304.8, 308	<input type="checkbox"/>		Combustion air provided	IMC 701	<input type="checkbox"/>	<input type="checkbox"/>	Ignition source elevated in hazardous locations	IMC 304.3	<input type="checkbox"/>	<input type="checkbox"/>	Oil tank removed if req'd		<p><u>Oil</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><u>Pass</u></td> <td style="width: 10%;"><u>N/A</u></td> <td style="width: 70%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Shut off valves installed</td> <td>IMC 1307</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Fuel oil piping complies with code</td> <td>IMC 1302</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Clearance to combustibles meets code</td> <td>IMC 304.8, 308</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Combustion air provided</td> <td>IMC 701</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Ignition source elevated in hazardous locations</td> <td>IMC 304.3</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Barometric damper installed</td> <td>IMC 803.6</td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td>Fuel oil tank and piping installed per code</td> <td>IMC Chapter 13</td> </tr> </table>	<u>Pass</u>	<u>N/A</u>			<input type="checkbox"/>		Shut off valves installed	IMC 1307	<input type="checkbox"/>		Fuel oil piping complies with code	IMC 1302	<input type="checkbox"/>		Clearance to combustibles meets code	IMC 304.8, 308	<input type="checkbox"/>		Combustion air provided	IMC 701	<input type="checkbox"/>	<input type="checkbox"/>	Ignition source elevated in hazardous locations	IMC 304.3	<input type="checkbox"/>		Barometric damper installed	IMC 803.6	<input type="checkbox"/>		Fuel oil tank and piping installed per code	IMC Chapter 13
<u>Pass</u>	<u>N/A</u>																																																												
<input type="checkbox"/>		Shut off valves installed	IFGC 409.1																																																										
<input type="checkbox"/>		Fuel gas piping inspected if req'd	IFGC 401.1																																																										
<input type="checkbox"/>		Clearance to combustibles	IMC 304.8, 308																																																										
<input type="checkbox"/>		Combustion air provided	IMC 701																																																										
<input type="checkbox"/>	<input type="checkbox"/>	Ignition source elevated in hazardous locations	IMC 304.3																																																										
<input type="checkbox"/>	<input type="checkbox"/>	Oil tank removed if req'd																																																											
<u>Pass</u>	<u>N/A</u>																																																												
<input type="checkbox"/>		Shut off valves installed	IMC 1307																																																										
<input type="checkbox"/>		Fuel oil piping complies with code	IMC 1302																																																										
<input type="checkbox"/>		Clearance to combustibles meets code	IMC 304.8, 308																																																										
<input type="checkbox"/>		Combustion air provided	IMC 701																																																										
<input type="checkbox"/>	<input type="checkbox"/>	Ignition source elevated in hazardous locations	IMC 304.3																																																										
<input type="checkbox"/>		Barometric damper installed	IMC 803.6																																																										
<input type="checkbox"/>		Fuel oil tank and piping installed per code	IMC Chapter 13																																																										

Boiler

<u>Pass</u>	<u>N/A</u>		
<input type="checkbox"/>		Water supply connection per	IMC 1005.1, 1005.2, 2015 IPC
<input type="checkbox"/>		Low-water cutoff control installed	IMC 1007
<input type="checkbox"/>		Boiler expansion tank installed	IMC 1009
<input type="checkbox"/>		Safety valves installed	IMC 1006
<input type="checkbox"/>		Pressure relief valve installed	IMC 1006

Installer Information (Lic No. _____)

License Holder Name _____

License Holder Signature _____

Date of Installation _____

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.